

2019-2020 Dakota Co. & MN Dept. of Health Private Drinking Water Well Results

Well Depth Range

- Shallow (< 125')
- △ MidDepth (125' - 250')
- Deep (> 250')

Combined Radium 226+228 Concentration (PCi/L) (n = 69)

Drinking water standard = 5 (PCi/L)

- < 0.5 (12)
- 0.5 - 2.5 (45)
- 2.5 - 5.0 (11)
- > 5.0 (2)

